

# VOC Content Test Certificate

Friday October 2<sup>nd</sup>, 2009

Manufacturer: Protect Crete Pty Ltd (14/137 Rooks Road, Nunawading Victoria 3131)

Sample Description: Luster Shield

Date Tested: September 2009 (Tested by FORAY Laboratories – NATA Accreditation 1231)

Test Method: ASTM D3960 Standard Practice for Determining Volatile Organic Compound (VOC) Content of Paints and Related Coatings.

Test Data:

<b>Specification</b>	
<b>Green Building Council of Australia</b>	<b>Luster Shield</b>
<b>Green Star Office Design V2 IEQ-13</b>	
<b>Green Star Office Interiors V1.1 IEQ-11</b>	
Interior Sealer 65 grams per Litre as VOC content coating	<b>&lt;1 grams per Litre as VOC content per coating</b>
<b>Specification</b>	
<b>Green Building Council of Australia</b>	<b>Luster Shield</b>
<b>Green Star Office Design V3 IEQ-13</b>	
Interior Sealer 65 grams per Litre as VOC content coating	<b>&lt;1 grams per Litre as VOC content per coating</b>



Dr. Vyt Garnys  
PhD, BSc(Hons) AIMM, ARACI, ISIAQ  
ACA, AIRAH, FMA  
Managing Director and Principal Consultant

**F0909-30**